

Architectural cross-section drawing of a basement wall and floor. The drawing shows a concrete wall with a central opening for a door (Ø 2000) and a window (Ø 600). The floor is made of reinforced concrete slabs (250x250x15 cm) with a cross-hatch pattern. The wall is labeled "BET. KL. B 55". The floor is labeled "IZOLACJA PRZECIWWILGOCIOWA". The door is labeled "PRZEJŚCIE SZCZELNE". The window is labeled "właz Ø 600". The drawing includes elevation markers: 139,75, 139,90, 138,35, 138,30, and 136,10. The door is labeled "klamry co 30 cm".

OBIEKT ADRES		Kanalizacja sanitarn., deszcz., sieć wodoc. Bielski Podlaski ul. Batorego, zaułek	
PRZEDMIOT SKALA I NR RYSUNKU		Studnia betonowa Ø 200 cm z osadnikiem Schemat	Rys. Nr 4
1. Projektant nr upr. bud 2. Sprawdzający nr upr. bud		1. mgr inż. MARIA J. JUSZCZYŃSKA BŁ/100/94 specj. instalac.-inżynieryjna	
DATA	PODPISY	2. inż. TADEUSZ WYSZKOWSKI BŁ/189/91 specj. instalac.-inżynieryjna	
29.12.2008 r.	2.		